

**PIELIETOJAMIE CAURUĻVADU SILTUMIZOLĀCIJAS
BIEZUMI RĪGAS PILSĒTAS CENTRALIZĒTĀS
SILTUMAPGĀDES SISTĒMĀ**

1.tabula

Virszemes siltumtīkliem

Caurules nosacītais diametrs DN, mm	Akmens vates čaulas		Akmens vates paklāji	
	s=100 kg/m ³ λ=0,046 W/mK	s=100 kg/m ³ λ=0,054 W/mK	s=80 kg/m ³ λ=0,046 W/mK	s=80 kg/m ³ λ=0,054 W/mK
	T ₂	T ₁	T ₂	T ₁
	70°C	130°C	70°C	130°C
15	40	60	-	-
20	40	60	-	-
25	40	60	-	-
32	40	60	-	-
40	50	60	-	-
50	50	80	-	-
65	50	80	50	80
80	50	80	50	80
100	60	80	60	80
125	60	80	60	80
150	60	100	60	100
200	60	100	60	100
250	60	100	60	100
300	60	100	60	100
350	80	100	80	100
400	80	120	80	120
500	80	120	80	120
600	80	120	80	120
700	100	140	100	140
800	100	140	100	140
900	100	140	100	140
1000	100	140	100	140
1200	120	160	120	160

„APSTIPRINU”

AS „RĪGAS SILTUMS”

Valdes loceklis

U.Osis

2021.g. „06”

janvārī

2.tabula

Pagrabos

Caurules nosacītais diametrs DN, mm	Akmens vates čaulas ar PVC aizsargapvalku		Akmens vates paklāji ar PVC aizsargapvalku	
	s=100 kg/m ³ λ=0,046 W/mK	s=100 kg/m ³ λ=0,054 W/mK	s=80 kg/m ³ λ=0,046 W/mK	s=80 kg/m ³ λ=0,054 W/mK
	T ₂	T ₁	T ₂	T ₁
	70°C	130°C	70°C	130°C
15	40	60	-	-
20	40	60	-	-
25	40	60	-	-
32	40	60	-	-
40	50	60	-	-
50	50	80	-	-
65	50	80	50	80
80	50	80	50	80
100	60	80	60	80
125	60	80	60	80
150	60	100	60	100
200	60	100	60	100
250	60	100	60	100
300	60	100	60	100
350	80	100	80	100
400	80	120	80	120
500	80	120	80	120

Siltumtīklu direktors	J.Zeiza	
Tehniskās daļas vadītājs	J.Mežītis	
MI dienesta vadītājs	I.Vanags	